

CERTIFICATE of Conformity



Registration No.: AK 50553833 0001

Report No.: CN22WH86 001

Holder: **SolaX Power Network Technology
(Zhe jiang) Co., Ltd.
No.288 Shizhu Road
Tonglu Economic Development Zone
Tonglu City,
Zhejiang Province 310000
P.R. China**

Product: **PV-Inverter
(Grid-Connected PV Inverter)**

Identification: Type Designation: X3-FTH-xK(x=80,100,110,120,125)
Serial Number : Engineering samples
Firmware Version: 9324.00019.00
Software Version: XFORTH V005.00
Remark(s) : Refer to report CN22WH86 001 for details.

Tested acc. to: CEI 0-21:2022-03

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Certification Body

Date 29.08.2022




Weichun Li

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

OGGETTO: Dichiarazione di conformità alla normativa CEI 0-21:2022-03

“Regola tecnica di riferimento per la connessione di Utenti attivi e passivi alle reti BT delle imprese distributrici di energia elettrica”

SUBJECT: Declaration of Conformity to CEI 0-21:2022-03

“Reference technical rules for the connection of active and passive users to the LV electrical Utilities”

Certificate No.: AK 50553833 0001

TIPOLOGIA DI APPARATO A CUI SI RIFERISCE LA DICHIARAZIONE:

TYPE OF APPARATUS WHICH THE DECLARATION IS REFERRED TO:

DISPOSITIVO DI INTERFACCIA Interface Device	PROTEZIONE DI INTERFACCIA Interface Protection Device	DISPOSITIVO DI CONVERSIONE STATICA Static Conversion Device	DISPOSITIVO DI GENERAZIONE ROTANTE Rotating Device
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Costruttore
Manufacturer

SolaX Power Network Technology (Zhe Jiang) Co., Ltd.

Modello/Tipo
Model/Type

Potenza Attiva Nominale (P_{NINV})
Nominal Power
[kW]

Max. Potenza Apparente (S_{MAX})
Maximum Apparent Power
[kVA]

X3-FTH-80K
X3-FTH-100K
X3-FTH-110K
X3-FTH-120K
X3-FTH-125K

80
100
110
120
125

88
110
121
132
132

^(*) The inverter have a PV input and AC output with the batteries system and it's compliant to Annex A, B and Bbis of standard CEI 0-21
The nominal charging and discharging power can be reached only according with a minimum number of battery modules connected to the inverter with limitation of the inverter's capability.

Firmware release
Firmware

9324.00019.00

Software release
Software

XFORTH V005.00

Numero di Fasi
Number of phases

3


Note
Remarks

Il dispositivo è in grado di limitare la Idc allo 0,5% della corrente nominale.
The device is capable to limit the Idc to 0,5% of the nominal current.

laboratorio di prova
Test laboratory

TÜV Rheinland (Shanghai) Co., Ltd.
Accreditation CNAS no. L3038

TÜV Rheinland LGA Products GmbH
Tillystraße 2 · 90431 Nürnberg · Germany

 **TÜVRheinland®**
Precisely Right.

Certificate No.: AK 50553833 0001

Page 2/2

Esaminati I Fascicoli Prove N.: CN22WH86 001 emesso da TÜV Rheinland (Shanghai) S.r.l.
Having assessed the Test Files N. CN22WH86 001 issued by TÜV Rheinland (Shanghai) Co., Ltd.

Si dichiara che i prodotti indicati soddisfano i requisiti della CEI 0-21:2022-03 "Regola tecnica di riferimento per la connessione di Utenti attivi e passivi alle reti BT delle imprese distributrici di energia elettrica"
We declare that the products indicated meet the requirements laid down by CEI 0-21:2022-03 "Reference technical rules for the connection of active and passive users to the LV electrical Utilities"

Validità della Dichiarazione
Validity of the Declaration


Questa Dichiarazione è valida per i prodotti indicate, così come descritt nei Fascicoli citati. Nuovi requisiti o emendamenti a requisiti esistenti, così come modifiche al prodotto, possono implicare nuove verifiche e certificazioni.
This Declaration is valid only for the products indicated herein, as described in the Files mentioned. New requirements or amendment to existing ones, or modifications to the product, may imply re-verification and re-certification.

Date: 29.08.2022

Signature :



TÜV Rheinland LGA Products GmbH
Tillystraße 2 · 90431 Nürnberg · Germany

 **TÜVRheinland®**
Precisely Right.